

**STATE OF NEW YORK
PUBLIC SERVICE COMMISSION**

-----X
Application of New York State Electric & Gas :
Corporation for a Certificate of Environmental :
Compatibility and Public Need Pursuant to : Case 24-T-
Article VII of the Public Service Law for the :
Jennison Transmission Solution Project :
-----X

**MOTION FOR WAIVER OF
APPLICATION REQUIREMENTS
OF NEW YORK STATE ELECTRIC &
GAS CORPORATION**

Pursuant to 16 NYCRR §§ 3.3 and 3.6, and as part of its filing of an application (“Application”) for a Certificate of Environmental Compatibility and Public Need for its Jennison Transmission Solution Project (“Project”), New York State Electric & Gas Corporation (“Applicant”) respectfully requests that the Commission waive or modify for the Application the following section of the Commission’s regulations:

16 NYCRR § 88.4(a)(4): Provide a copy of the system reliability impact study forwarded by the Transmission Planning Advisory Subcommittee.

The Applicant requests waiver of the requirement that Exhibit E-4 of the Application include a system reliability impact study or system impact study (“SIS”). The New York Independent System Operator (“NYISO”) does not require an SRIS or SIS to be performed if the proposed transmission project is expected to not reduce interface Transfer Capability by more than 10 MW and not increase interface Transfer Capability by more than 25 MW. As stated in Exhibit E-4, the Applicant performed all the necessary analyses for an SIS screening in consultation with the NYISO and determined that a SIS is not necessary for the Project. The NYISO agreed. This is documented in the correspondence, dated October 25, 2023, provided as Attachment E-4-A to Exhibit E-4.

Dated: December 4, 2024

Respectfully submitted,

New York State Electric & Gas Corporation

By: /s/ David T. Metcalfe
David T. Metcalfe
Cullen and Dykman LLP
Its Attorneys